



Pete K. Rahn, Director

ADDENDUM 001
REQUEST FOR Quotation
D610-083-RW Demolition Rte 141

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with original bid. The due date for receipt of this proposal **does not change** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Terri Mount Sr. General Services Specialist
Bidder Signature	Department of Transportation <i>Terri Mount</i>
Signature of person authorized to sign	Authorizing Signature
Date Signed:	Date Signed: 12-08-09 @ 2:00 p.m.

Question: Does MoDOT expect the foundation openings left by the demolition to be filled to ground level to eliminate standing pools of water? If so should the contractor plan on importing material for fill?

MoDOT Response:

For the answer to your backfill and grading question see Exhibit B, MoDOT Standard Specifications, Section 202.3.4, Backfill and also Exhibit C, Demolition and Removal Specifications, Section 8.0, Future Excavation. Both parcels are relatively flat so obtaining backfill material from the parcels will be difficult without causing ponding issues. Therefore Section 8.2 of Exhibit C requires backfill to be from a source furnished by the contractor. Section 202.3.4 of Exhibit B requires the backfilled and finished areas to properly drain.

THIS ADDENDUM MUST BE SIGNED AND RETURNED WITH QUOTATION